April 19, 2013

Duke Energy
Miami Fort Generating Station
11021 Brower Road
North Bend, OH 45052

Attention: Mr. Michael Byrd
Environmental Coordinator

Re: Results – **April 2013**
Low-Level Mercury Sampling
Miami Fort Generating Station
North Bend, Ohio

In accordance with your request, URS prepared the following letter report transmitting low-level mercury test results for samples collected at the Miami Fort Generating Station located in North Bend, Ohio.

The scope of work involved the sampling of intake and discharge waters from the following sources and analysis of those samples for low-level mercury.

1. River Intake
2. Station 601 (WWT Influent)
   [Samples were collected at this station one detention time (approximately 14 hours as specified by Duke Energy) before samples collected at Outfall 608]
3. Outfall 608 (WWT Effluent)
   [Samples were collected at this outfall one detention time (approximately 14 hours as specified by Duke Energy) after samples collected at station 601]
4. Outfall 002 (Pond B Discharge)

Each sample was collected following the required Method 1669: *Sampling Ambient Water for Determination of Trace Metals at EPA Water Quality Criteria Levels* (Sampling Method) and analyzed by Method 1631E. At the request of Duke Energy, a dissolved low-level mercury sample was collected by Method 1669 from Outfall 608 and analyzed by Method 1631E. The collected dissolved sample was filtered at the laboratory utilizing 0.45 micron filtration.

Field staff from URS' Cincinnati office conducted the sampling and TestAmerica Laboratories Inc. located in North Canton, Ohio performed the analytical procedures. The analytical procedures included the analyses of a collected sample and duplicate sample (duplicates collected at Outfall 608 and Outfall 002), field blank (field blanks collected at the River Intake, Outfall 608, and Outfall 002), and trip blank.

URS Corporation
525 Vine Street, Suite 1800
Cincinnati, Ohio 45202
Tel: 513.651.3440
Fax: 1.877.660.7720 (toll free)

The results from the **April 1 and 2, 2013** sampling events are presented in the attached Table 1. A copy of the laboratory report is enclosed with this letter.

--ooOoo--

URS is pleased to provide continued assistance to Duke Energy in the execution of their environmental monitoring requirements. If there are any questions regarding the content of this report, please do not hesitate to contact the undersigned.

Sincerely,

URS Corporation

Michael A. Wagner
Project Manager

Dennis P. Connair, C.P.G.
Principal

MAW/DPC/Duke Energy-MFS LL Hg 2013
Job No. 14951061

TABLE 1

ANALYTICAL RESULTS
LOW-LEVEL MERCURY
RIVER INTAKE, STATION 601, OUTFALL 608, AND OUTFALL 002 (POND B)

DUKE ENERGY - MIAMI FORT STATION
NORTH BEND, OHIO

	Date Sampled / Results (ng/L, parts per trillion)					
Sample ID	**1/2-3/2013**	**2/4-5/2013**	**3/4-5/2013**	**4/1-2/2013**	**5/xx/2013**	**6/xx/2013**
River Intake	4.1	15	6.0	2.1		
Station 601 (7)	730,000	320,000	82,000	94,000		
Station 601 (7) [duplicate]	Not Collected	Not Collected	Not Collected	Not Collected		
Station 601 (8)	330,000	370,000	140,000	130,000		
Station 601 (8) [duplicate]	Not Collected	Not Collected	Not Collected	Not Collected		
Outfall 608	50	54	110	49		
Outfall 608 [duplicate]	46	55	110	50		
Outfall 608 [dissolved, 0.45 micron]	0.63	<0.50	1.2	<0.50		
APB-002	5.1	9.1	4.8	1.9		
APB-002 [duplicate]	5.3	9.3	4.8	1.8		
Field Blank (RI-FB)	1.0	1.2	2.5	1.6		
Field Blank (WWT-FB)	<0.50	<0.50	9.1	<0.50		
Field Blank (AP-FB)	<0.50	<0.50	<0.50	<0.50		
Trip Blank	<0.50	<0.50	<0.50	<0.50		

Samples collected by URS (Method 1669)
Sampling times are noted within the associated laboratory report for each collected sample
Samples analyzed by TestAmerica of North Canton, Ohio (Method 1631E).

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Canton
4101 Shuffel Street NW
North Canton, OH 44720
Tel: (330)497-9396

TestAmerica Job ID: 240-22758-1
Client Project/Site: Duke MF 2013 LLHg - J13040138

For:
Duke Energy Corporation
139 East Fourth Street
Cincinnati, Ohio 45202

Attn: Tara Thomas

Denise Pohl

Authorized for release by:
4/17/2013 5:53:25 PM

Denise Pohl
Project Manager II
denise.pohl@testamericainc.com

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Definitions/Glossary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Qualifiers

Metals

Qualifier	Qualifier Description
F	MS or MSD exceeds the control limits
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Job ID: 240-22758-1

Laboratory: TestAmerica Canton

Narrative

CASE NARRATIVE

Client: Duke Energy Corporation

Project: Duke MF 2013 LLHg - J13040138

Report Number: 240-22758-1

With the exceptions noted as flags or footnotes, standard analytical protocols were followed in the analysis of the samples and no problems were encountered or anomalies observed. In addition all laboratory quality control samples were within established control limits, with any exceptions noted below. Each sample was analyzed to achieve the lowest possible reporting limit within the constraints of the method. In some cases, due to interference or analytes present at high concentrations, samples were diluted. For diluted samples, the reporting limits are adjusted relative to the dilution required.

TestAmerica Canton attests to the validity of the laboratory data generated by TestAmerica facilities reported herein. All analyses performed by TestAmerica facilities were done using established laboratory SOPs that incorporate QA/QC procedures described in the application methods. TestAmerica's operations groups have reviewed the data for compliance with the laboratory QA/QC plan, and data have been found to be compliant with laboratory protocols unless otherwise noted below.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory.

Calculations are performed before rounding to avoid round-off errors in calculated results.

All holding times were met and proper preservation noted for the methods performed on these samples, unless otherwise detailed in the individual sections below.

All solid sample results are reported on an "as received" basis unless otherwise indicated by the presence of a % solids value in the method header.

This laboratory report is confidential and is intended for the sole use of TestAmerica and its client.

RECEIPT

The samples were received on 04/03/2013; the samples arrived in good condition. The temperature of the cooler at receipt was 13.4 C.

DISSOLVED LOW LEVEL MERCURY

Sample 608 WWT DISS (240-22758-8) was analyzed for dissolved low level mercury in accordance with EPA Method 1631E. The samples were prepared on 04/04/2013 and analyzed on 04/05/2013.

No difficulties were encountered during the Low Level Mercury analysis.

All quality control parameters were within the acceptance limits.

LOW LEVEL MERCURY

Samples RI FB (240-22758-1), RI (240-22758-2), 601 (7) WWT (240-22758-3), 601 (8) WWT (240-22758-4), 608 WWT FB (240-22758-5), 608 WWT (240-22758-6), 608 WWT DUP (240-22758-7), OUTFALL 002 FB (240-22758-9), OUTFALL 002 (240-22758-10), OUTFALL 002 DUP (240-22758-11) and TRIP BLANK (240-22758-12) were analyzed for Low Level Mercury in accordance with EPA Method 1631E. The samples were prepared on 04/04/2013 and analyzed on 04/05/2013.

Mercury failed the recovery criteria low for the MS/MSD of sample OUTFALL 002 DUPMS/MSD (240-22758-11) in batch 240-81141.

Job ID: 240-22758-1 (Continued)

Laboratory: TestAmerica Canton (Continued)

Refer to the QC report for details.

Samples 601 (7) WWT (240-22758-3)[100000X], 601 (8) WWT (240-22758-4)[100000X], 608 WWT (240-22758-6)[10X] and 608 WWT DUP (240-22758-7)[10X] required dilution prior to analysis. The reporting limits have been adjusted accordingly.

No other difficulties were encountered during the Low Level Mercury analyses.

All other quality control parameters were within the acceptance limits.

Method Summary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Method	Method Description	Protocol	Laboratory
1631E	Mercury, Low Level (CVAFS)	EPA	TAL CAN

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

TAL CAN = TestAmerica Canton, 4101 Shuffel Street NW, North Canton, OH 44720, TEL (330)497-9396

Sample Summary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
240-22758-1	RI FB	Water	04/01/13 16:55	04/03/13 09:00
240-22758-2	RI	Water	04/01/13 17:00	04/03/13 09:00
240-22758-3	601 (7) WWT	Water	04/01/13 17:25	04/03/13 09:00
240-22758-4	601 (8) WWT	Water	04/01/13 17:35	04/03/13 09:00
240-22758-5	608 WWT FB	Water	04/02/13 08:20	04/03/13 09:00
240-22758-6	608 WWT	Water	04/02/13 08:25	04/03/13 09:00
240-22758-7	608 WWT DUP	Water	04/02/13 08:30	04/03/13 09:00
240-22758-8	608 WWT DISS	Water	04/02/13 08:35	04/03/13 09:00
240-22758-9	OUTFALL 002 FB	Water	04/02/13 08:50	04/03/13 09:00
240-22758-10	OUTFALL 002	Water	04/02/13 08:55	04/03/13 09:00
240-22758-11	OUTFALL 002 DUP	Water	04/02/13 09:00	04/03/13 09:00
240-22758-12	TRIP BLANK	Water	04/01/13 00:00	04/03/13 09:00

Detection Summary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: RI FB — Lab Sample ID: 240-22758-1

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	1.6		0.50		ng/L	1		1631E	Total/NA

Client Sample ID: RI — Lab Sample ID: 240-22758-2

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	2.1		0.50		ng/L	1		1631E	Total/NA

Client Sample ID: 601 (7) WWT — Lab Sample ID: 240-22758-3

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	94000		50000		ng/L	100000		1631E	Total/NA

Client Sample ID: 601 (8) WWT — Lab Sample ID: 240-22758-4

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	130000		50000		ng/L	100000		1631E	Total/NA

Client Sample ID: 608 WWT FB — Lab Sample ID: 240-22758-5

No Detections.

Client Sample ID: 608 WWT — Lab Sample ID: 240-22758-6

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	49		5.0		ng/L	10		1631E	Total/NA

Client Sample ID: 608 WWT DUP — Lab Sample ID: 240-22758-7

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	50		5.0		ng/L	10		1631E	Total/NA

Client Sample ID: 608 WWT DISS — Lab Sample ID: 240-22758-8

No Detections.

Client Sample ID: OUTFALL 002 FB — Lab Sample ID: 240-22758-9

No Detections.

Client Sample ID: OUTFALL 002 — Lab Sample ID: 240-22758-10

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	1.9		0.50		ng/L	1		1631E	Total/NA

Client Sample ID: OUTFALL 002 DUP — Lab Sample ID: 240-22758-11

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Mercury	1.8		0.50		ng/L	1		1631E	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: TRIP BLANK **Lab Sample ID: 240-22758-12**

No Detections.

This Detection Summary does not include radiochemical test results.

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: RI FB
Date Collected: 04/01/13 16:55
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-1
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	1.6		0.50		ng/L		04/04/13 11:02	04/05/13 14:54	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: RI
Date Collected: 04/01/13 17:00
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-2
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	2.1		0.50		ng/L		04/04/13 11:02	04/05/13 14:58	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 601 (7) WWT
Date Collected: 04/01/13 17:25
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-3
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	94000		50000		ng/L		04/04/13 11:02	04/05/13 15:02	100000

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 601 (8) WWT
Date Collected: 04/01/13 17:35
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-4
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	130000		50000		ng/L		04/04/13 11:02	04/05/13 15:06	100000

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 608 WWT FB
Date Collected: 04/02/13 08:20
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-5
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 11:02	04/05/13 15:11	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 608 WWT
Date Collected: 04/02/13 08:25
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-6
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	49		5.0		ng/L		04/04/13 11:02	04/05/13 15:15	10

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 608 WWT DUP
Date Collected: 04/02/13 08:30
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-7
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	50		5.0		ng/L		04/04/13 11:02	04/05/13 15:20	10

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: 608 WWT DISS
Date Collected: 04/02/13 08:35
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-8
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS) - Dissolved

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 10:47	04/05/13 11:52	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: OUTFALL 002 FB
Date Collected: 04/02/13 08:50
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-9
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 11:02	04/05/13 15:24	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: OUTFALL 002
Date Collected: 04/02/13 08:55
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-10
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	1.9		0.50		ng/L		04/04/13 11:02	04/05/13 15:37	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: OUTFALL 002 DUP
Date Collected: 04/02/13 09:00
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-11
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	1.8		0.50		ng/L		04/04/13 11:02	04/05/13 15:41	1

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: TRIP BLANK
Date Collected: 04/01/13 00:00
Date Received: 04/03/13 09:00

Lab Sample ID: 240-22758-12
Matrix: Water

Method: 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 11:02	04/05/13 15:54	1

Method: 1631E - Mercury, Low Level (CVAFS)

Lab Sample ID: MB 240-80586/1-A — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80586**

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 10:47	04/05/13 11:22	1

Lab Sample ID: LCS 240-80586/2-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80586**

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits		
Mercury			5.00	4.48		ng/L		90	77 - 123		

Lab Sample ID: MB 240-80772/1-A — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80772**

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 11:02	04/05/13 13:40	1

Lab Sample ID: LCS 240-80772/2-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80772**

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits		
Mercury			5.00	4.31		ng/L		86	77 - 123		

Lab Sample ID: 240-22758-11 MS — **Client Sample ID: OUTFALL 002 DUP**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80772**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits		
Mercury	1.8		5.00	4.63	F	ng/L		56	71 - 125		

Lab Sample ID: 240-22758-11 MSD — **Client Sample ID: OUTFALL 002 DUP**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 81141 — **Prep Batch: 80772**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Mercury	1.8		5.00	4.30	F	ng/L		49	71 - 125	7	24

Lab Sample ID: PB 240-80583/1-B PB — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Dissolved**
Analysis Batch: 81141 — **Prep Batch: 80586**

Analyte	PB Result	PB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.50	U	0.50		ng/L		04/04/13 10:47	04/05/13 11:31	1

Metals

Prep Batch: 80586

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
240-22758-8	608 WWT DISS	Dissolved	Water	1631E	
LCS 240-80586/2-A	Lab Control Sample	Total/NA	Water	1631E	
MB 240-80586/1-A	Method Blank	Total/NA	Water	1631E	
PB 240-80583/1-B PB	Method Blank	Dissolved	Water	1631E	

Prep Batch: 80772

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
240-22758-1	RI FB	Total/NA	Water	1631E	
240-22758-2	RI	Total/NA	Water	1631E	
240-22758-3	601 (7) WWT	Total/NA	Water	1631E	
240-22758-4	601 (8) WWT	Total/NA	Water	1631E	
240-22758-5	608 WWT FB	Total/NA	Water	1631E	
240-22758-6	608 WWT	Total/NA	Water	1631E	
240-22758-7	608 WWT DUP	Total/NA	Water	1631E	
240-22758-9	OUTFALL 002 FB	Total/NA	Water	1631E	
240-22758-10	OUTFALL 002	Total/NA	Water	1631E	
240-22758-11	OUTFALL 002 DUP	Total/NA	Water	1631E	
240-22758-11 MS	OUTFALL 002 DUP	Total/NA	Water	1631E	
240-22758-11 MSD	OUTFALL 002 DUP	Total/NA	Water	1631E	
240-22758-12	TRIP BLANK	Total/NA	Water	1631E	
LCS 240-80772/2-A	Lab Control Sample	Total/NA	Water	1631E	
MB 240-80772/1-A	Method Blank	Total/NA	Water	1631E	

Analysis Batch: 81141

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
240-22758-1	RI FB	Total/NA	Water	1631E	80772
240-22758-2	RI	Total/NA	Water	1631E	80772
240-22758-3	601 (7) WWT	Total/NA	Water	1631E	80772
240-22758-4	601 (8) WWT	Total/NA	Water	1631E	80772
240-22758-5	608 WWT FB	Total/NA	Water	1631E	80772
240-22758-6	608 WWT	Total/NA	Water	1631E	80772
240-22758-7	608 WWT DUP	Total/NA	Water	1631E	80772
240-22758-8	608 WWT DISS	Dissolved	Water	1631E	80586
240-22758-9	OUTFALL 002 FB	Total/NA	Water	1631E	80772
240-22758-10	OUTFALL 002	Total/NA	Water	1631E	80772
240-22758-11	OUTFALL 002 DUP	Total/NA	Water	1631E	80772
240-22758-11 MS	OUTFALL 002 DUP	Total/NA	Water	1631E	80772
240-22758-11 MSD	OUTFALL 002 DUP	Total/NA	Water	1631E	80772
240-22758-12	TRIP BLANK	Total/NA	Water	1631E	80772
LCS 240-80586/2-A	Lab Control Sample	Total/NA	Water	1631E	80586
LCS 240-80772/2-A	Lab Control Sample	Total/NA	Water	1631E	80772
MB 240-80586/1-A	Method Blank	Total/NA	Water	1631E	80586
MB 240-80772/1-A	Method Blank	Total/NA	Water	1631E	80772
PB 240-80583/1-B PB	Method Blank	Dissolved	Water	1631E	80586

Lab Chronicle

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Client Sample ID: RI FB
Lab Sample ID: 240-22758-1
Date Collected: 04/01/13 16:55
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 14:54	DH	TAL CAN

Client Sample ID: RI
Lab Sample ID: 240-22758-2
Date Collected: 04/01/13 17:00
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 14:58	DH	TAL CAN

Client Sample ID: 601 (7) WWT
Lab Sample ID: 240-22758-3
Date Collected: 04/01/13 17:25
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		100000	81141	04/05/13 15:02	DH	TAL CAN

Client Sample ID: 601 (8) WWT
Lab Sample ID: 240-22758-4
Date Collected: 04/01/13 17:35
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		100000	81141	04/05/13 15:06	DH	TAL CAN

Client Sample ID: 608 WWT FB
Lab Sample ID: 240-22758-5
Date Collected: 04/02/13 08:20
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 15:11	DH	TAL CAN

Client Sample ID: 608 WWT
Lab Sample ID: 240-22758-6
Date Collected: 04/02/13 08:25
Matrix: Water
Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		10	81141	04/05/13 15:15	DH	TAL CAN

Client Sample ID: 608 WWT DUP

Lab Sample ID: 240-22758-7

Date Collected: 04/02/13 08:30

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		10	81141	04/05/13 15:20	DH	TAL CAN

Client Sample ID: 608 WWT DISS

Lab Sample ID: 240-22758-8

Date Collected: 04/02/13 08:35

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Dissolved	Prep	1631E			80586	04/04/13 10:47	DH	TAL CAN
Dissolved	Analysis	1631E		1	81141	04/05/13 11:52	DH	TAL CAN

Client Sample ID: OUTFALL 002 FB

Lab Sample ID: 240-22758-9

Date Collected: 04/02/13 08:50

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 15:24	DH	TAL CAN

Client Sample ID: OUTFALL 002

Lab Sample ID: 240-22758-10

Date Collected: 04/02/13 08:55

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 15:37	DH	TAL CAN

Client Sample ID: OUTFALL 002 DUP

Lab Sample ID: 240-22758-11

Date Collected: 04/02/13 09:00

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 15:41	DH	TAL CAN

Client Sample ID: TRIP BLANK

Lab Sample ID: 240-22758-12

Date Collected: 04/01/13 00:00

Matrix: Water

Date Received: 04/03/13 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			80772	04/04/13 11:02	DH	TAL CAN
Total/NA	Analysis	1631E		1	81141	04/05/13 15:54	DH	TAL CAN

Lab Chronicle

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Laboratory References:

TAL CAN = TestAmerica Canton, 4101 Shuffel Street NW, North Canton, OH 44720, TEL (330)497-9396

Certification Summary

Client: Duke Energy Corporation
Project/Site: Duke MF 2013 LLHg - J13040138

TestAmerica Job ID: 240-22758-1

Laboratory: TestAmerica Canton

All certifications held by this laboratory are listed. Not all certifications are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
California	NELAP	9	01144CA	06-30-13
Connecticut	State Program	1	PH-0590	12-31-13
Florida	NELAP	4	E87225	06-30-13
Georgia	State Program	4	N/A	06-30-13
Illinois	NELAP	5	200004	07-31-13
Kansas	NELAP	7	E-10336	01-31-14
Kentucky	State Program	4	58	06-30-13
L-A-B	DoD ELAP		L2315	07-28-13
Minnesota	NELAP	5	039-999-348	12-31-13
Nevada	State Program	9	OH-000482008A	07-31-13
New Jersey	NELAP	2	OH001	06-30-13
New York	NELAP	2	10975	04-01-14
Ohio VAP	State Program	5	CL0024	01-19-14
Pennsylvania	NELAP	3	68-00340	08-31-13
Texas	NELAP	6		08-03-13
USDA	Federal		P330-11-00328	08-26-14
Virginia	NELAP	3	460175	09-14-13
Washington	State Program	10	C971	01-12-14
West Virginia DEP	State Program	3	210	12-31-13
Wisconsin	State Program	5	999518190	08-31-13

Chain of Custody Record

TestAmerica
THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Laboratory location: N. CANTON, OH.
Regulatory program: ☐ DW ☐ NPDES ☐ RCRA ☐ Other _____

TestAmerica Laboratories, Inc.

Client Contact				
Company Name: DUKE ENERGY -	Client Project Manager: M. WAGNER (URS)	Site Contact: J. ALTEN (URS)	Lab Contact: D. POHL	COC No: 053197
Address: MIAMI FORT STATION	Telephone: 513-651-3440	Telephone: 513-651-3440	Telephone:	1 of 2 COCs
City/State/Zip: N. BEND, OHIO	Email: mike.wagner@urs.com	Analysis Turnaround Time (in BUS days)	Analyses	For lab use only
Phone: (513)		TAT if different from below: CONTRACT ☐ 3 weeks ☐ 2 weeks ☐ 1 week ☐ 2 days ☐ 1 day		Walk-in client ☐ Lab pickup ☐ Lab sampling ☐
Project Name: DUKE MF 2013 LLHg	Method of Shipment/Carrier:			
Project Number: 14951061	Shipping/Tracking No:			Job/SDG No:
PO #				

Sample Identification	Sample Date	Sample Time	Matrix: Air	Aqueous	Sediment	Solid	Other:	Containers & Preservatives: H2SO4	HNO3	HCl	NaOH	ZnAc/NaOH	Unpres	Other:	Filtered Sample (Y/N)	Composite=C / Grab=G	Analyses: LL Hg	Sample Specific Notes / Special Instructions:
RI FB	04-01-13	1655		X									2		N	G	X	
RI		1700		X									4		N		X	
*601(7) WWT		1725		X									4				X	
*601(8) WWT		1735		X									4				X	
608 WWT FB	04-02-13	0820		X									2				X	
608 WWT		0825		X									4				X	
608 WWT Dup		0830		X									4				X	
608 WWT DISS		0835		X									4				X	
OUT FALL 002 FB		0850		X									2				X	
OUTFALL 002		0855		X									4				X	

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return to Client ☒ Disposal By Lab ☐ Archive For _____ Months

Special Instructions/QC Requirements & Comments:
* potentially elevated Hg

Relinquished by:	Company:	Date/Time:	Received by:	Company:	Date/Time:
	URS	04-02-13 1600		Test America	4/2/13 1600
Relinquished by:	Company:	Date/Time:	Received by:	Company:	Date/Time:
	Test America	4-2-13 1616		TA	4-3-13 900
Relinquished by:	Company:	Date/Time:	Received in Laboratory by:	Company:	Date/Time:

TAL 0018- 1 (04/10)

Chain of Custody Record

TestAmerica
THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Laboratory location: N. CANTON

Regulatory program: ☐ DW ☐ NPDES ☐ RCRA ☐ Other _____

TestAmerica Laboratories, Inc.

Client Contact				
Company Name:	Client Project Manager:	Site Contact:	Lab Contact:	COC No: 053198
Address:	Telephone:	Telephone:	Telephone:	2 of 2 COCs
City/State/Zip:	Email:	Analysis Turnaround Time (in BUS days)	Analyses	For lab use only
Phone:		TAT if different from below _____ ☐ 3 weeks ☐ 2 weeks ☐ 1 week ☐ 2 days ☐ 1 day		Walk-in client ☐ Lab pickup ☐ Lab sampling ☐
Project Name: DUKE MF 2013 LLHg	Method of Shipment/Carrier:			Job/SDG No:
Project Number: 14951061	Shipping/Tracking No:			
PO #				

Sample Identification	Sample Date	Sample Time	Matrix: Air	Aqueous	Sediment	Solid	Other:	Containers & Preservatives: H2SO4	HNO3	HCl	NaOH	ZnAc/ NaOH	Unpres	Other:	Filtered Sample (Y/N)	Composite C / Grab G	LLHg	Sample Specific Notes / Special Instructions:
OUTFALL 002 Dup	4-2-13	0900		X									4		N	G	X	
TRIP BLANK	—	—		X									2		—	—	X	

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return to Client ☒ Disposal By Lab ☐ Archive For _____ Months

Special Instructions/QC Requirements & Comments:

Relinquished by:	Company:	Date/Time:	Received by:	Company:	Date/Time:
	URS	04-02-13 1600		TestAmerica	4/2/13 1600
Relinquished by:	Company:	Date/Time:	Received by:	Company:	Date/Time:
	TestAmerica	4-2-13 1610		TA	4-3-13 900
Relinquished by:	Company:	Date/Time:	Received in Laboratory by:	Company:	Date/Time:

TAL 0018- 1 (04/10)

4/17/2013

TestAmerica Canton Sample Receipt Form/Narrative Login # : 22758

Client Duke Energy Site Name ______ By: [signature] (Signature)

Cooler Received on 4-3-13 Opened on 4-3-13

FedEx: 1st (Grd) Exp UPS FAS Stetson Client Drop Off TestAmerica Courier Other ______

TestAmerica Cooler # S049 Foam Box Client Cooler Box Other ______

Packing material used: (Bubble Wrap) Foam Plastic Bag None Other ______

COOLANT: ~~Wet Ice~~ Blue Ice Dry Ice Water (None)

1. Cooler temperature upon receipt

IR GUN# 1 (CF 0°C)	Observed Sample Temp. ____ °C	Corrected Sample Temp. ____ °C	
IR GUN# 4G (CF +1°C)	Observed Sample Temp. 12.4 °C	Corrected Sample Temp. 13.4 °C	☐ Multiple on Back
IR GUN# 5G (CF +1 °C)	Observed Sample Temp. ____ °C	Corrected Sample Temp. ____ °C	
IR GUN# 8 (CF +1°C)	Observed Sample Temp. ____ °C	Corrected Sample Temp. ____ °C	

2. Were custody seals on the outside of the cooler(s)? If Yes Quantity 1 — (Yes) No
   - -Were custody seals on the outside of the cooler(s) signed & dated? — (Yes) No NA
   - -Were custody seals on the bottle(s)? — Yes (No)
3. Shippers' packing slip attached to the cooler(s)? — (Yes) No
4. Did custody papers accompany the sample(s)? — (Yes) No
5. Were the custody papers relinquished & signed in the appropriate place? — (Yes) No
6. Did all bottles arrive in good condition (Unbroken)? — (Yes) No
7. Could all bottle labels be reconciled with the COC? — (Yes) No
8. Were correct bottle(s) used for the test(s) indicated? — (Yes) No
9. Sufficient quantity received to perform indicated analyses? — (Yes) No
10. Were sample(s) at the correct pH upon receipt? — Yes No (NA)
11. Were VOAs on the COC? — Yes (No)
12. Were air bubbles >6 mm in any VOA vials? — Yes No (NA)
13. Was a trip blank present in the cooler(s)? — (Yes) No

Contacted PM ______ Date ______ by ______ via Verbal Voice Mail Other

Concerning ______

14. CHAIN OF CUSTODY & SAMPLE DISCREPANCIES

High temp, ok, low level samples

15. SAMPLE CONDITION

Sample(s) ______ were received after the recommended holding time had expired.

Sample(s) ______ were received in a broken container.

Sample(s) ______ were received with bubble >6 mm in diameter. (Notify PM)

SOP: NC-SC-0005, Sample Receiving
C:\Documents and Settings\burnst\Local Settings\Temporary Internet Files\OLK3A\COOLER_TestAmerica_Rev 89_040213 rls.doc

16. SAMPLE PRESERVATION

Sample(s) ______________________________________ were further preserved in Sample Receiving to meet recommended pH level(s).

Nitric Acid Lot# 031512-HNO3; Sulfuric Acid Lot# 051012-H2SO4; Sodium Hydroxide and Zinc Acetate Lot# 100108-(CH3COO)2ZN/NaOH.

What time was preservative added to sample(s)? ______________________

Client ID	pH	Date	Initials
	pH Strip Lot# HC256691		

Cooler #	Observed Sample Temp. °C	Corrected Sample Temp. °C	IR #	Coolant